

कार्यालय सिविल सर्जन,

यमुनानगर - 135001 फोन नः 01732-237811, ई-मेल dhs.csynr@hry.nic.in



CERTIFICATE FOR SAFE DRINKING WATER AND SANITARY CONDITION

Letter No. ESYND/CON/ 2024 /133

Dated: 20/3/24

It is certified that an inspection team of <u>Health Department Yamuna Nagar</u> inspected the <u>Delhi Public School Bhambhol Yamuna Nagar</u> and found that the <u>Delhi Public School</u> has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year Only.

Signature with Seal:

Name : Dr Vageesh Gutain

Designation : Dy Civil Surgeon (Health)

Name & Address of the Office / Department

Office of Civil Surgeon Yamuna Nagar

Health Department Yamuna Nagar

To

Delhi Public School Bhambhol Yamuna Nagar From

Lab In charge DPHL- IDSP Laboratory Mukund Lal District Civil Hospital Yamuna Nagar

То

Medical Officer, PHC Bhambol.

No.

DML/YNR/2024/6 \

Dated: 15.3.24

Subject: Bacteriological Examination of Water Samples

In reference to letter No 19/BBL/2024

The report of water samples sent by you is as under: -

Dated: 7.03.2024

Sr. No.	Particulars of water Samples (With Complete Address)	OT Test Report For Chlorine	Test Report of Water for Bacteriological Examination
1.	Public health G.P.S HASANPUR	NIL	No. of coliform organisms seen 4 Water quality is Suspicious (Class III) Water is fit for human consumption
2.	Public health G.P.S HARIPUR JATTAN	NIL	No. of coliform organisms seen 0 Per 100ml. of water Water quality is Excellent (Class I) Water is fit for human consumption
3.	Public health D.P.S BHAMBOLI (TAB NO. 1)	NIL	No. of coliform organisms seen 0 Per 100ml. of water Water quality is Excellent (Class I) Water is fit for human consumption
4.	Public health D.P.S BHAMBOLI (TAB NO. 2)	NIL	No. of coliform organisms seen 0 Per 100ml. of water Water quality is Excellent (Class I) Water is fit for human consumption

Microbiologist

Incharge DPHL- IDSP Laboratory Mukand Lal District Civil Hospital

Yamuna Nagar